

Loss Prevention Certification Board



This is to certify

FIREGUARD SAFETY EQUIPMENT CO LTD
2nd Floor, 145-157 St John Street, London, EC1V 4PY,
United Kingdom

is authorised to use the LPCB mark in association with the
product(s) listed in this certificate and appendix.

Fireguard FG323-2L Heat Detector
(refer to attached appendix for details)

which has complied with the requirements of the following:

**EN 54-5: 2000 + A1 : 2002 Fire detection and fire alarm systems -
- Heat detectors - Point detectors**


Certificate No. 512d-(cl-4)


Issue No. 01

Date of Issue 21 August 2008

This certificate is valid until withdrawn by LPCB.
To check the validity and the authenticity of this certificate please
visit our website www.RedBookLive.com or contact us.

Signed on behalf of the LPCB


Name: N DANIYEL



LPCB is part of BRE Certification Ltd., Garston, Watford WD25 9XX. Tel +44 (0)1923 664100
Fax +44 (0)1923 664603 www.RedBookLive.com

This certificate remains the property of BRE Certification Ltd and is issued subject to terms and conditions
and is maintained and held in force through regular surveillance activities.

Loss Prevention Certification Board



APPENDIX TO CERTIFICATE NO. 512d-(cl-4)

FIREGUARD SAFETY EQUIPMENT CO LTD

Products

LPCB Ref. No.

Fireguard FG323-2L

Conventional 2 wire 24VDC class A2R fixed temperature and rate-of-rise heat detector with LED output (Fireguard P/N FG854001 base)

512d/04

Base:

Fireguard P/N FG854001

4-Wire detector base

This certificate is valid until withdrawn by LPCB.
To check the validity and the authenticity of this certificate please visit our website www.RedBookLive.com or contact us.

Signed on behalf of the LPCB

Page 2 of 2

Date of Issue 21 August 2008

Issue No. 01

Name:  N DANIEL

LPCB is part of BRE Certification Ltd., Garston, Watford WD25 9XX. Tel +44 (0)1923 664100
Fax +44 (0)1923 664603 www.RedBookLive.com

This certificate remains the property of BRE Certification Ltd and is issued subject to terms and conditions and is maintained and held in force through regular surveillance activities.