

## Search Results

You are here: [Home](#) » Search Results

### Alarm warning devices

#### **Fireguard Global Ltd.**

Unit 11 Chancel Industrial Estate  
Newhall Street  
Willenhall  
West Midlands  
WV13 1NX  
United Kingdom

Tel: +44 (0)8450 751042 • Fax: +44 (0)845 2991039  
Email: [info@fireguard-uk.com](mailto:info@fireguard-uk.com) • Web: [www.fireguard-uk.com](http://www.fireguard-uk.com)

#### **Certificate No 506e-(ci-1) to EN 54-3:2001 + A1:2002 + A2:2006**

Product	Description	LPCB Ref. No.
FG-0218	Conventional Fire Alarm Bell	506e/01
FG-03127S	Conventional Type B Electronic Sounder (FG-03127MB)  Note: Meets the requirements of EN 54-3:2001 at the following tones: 1 - Alternating Tones 800/970Hz at 2Hz 2 - Sweeping 800/970Hz at 7Hz	506e/02
FG-03127BS	Conventional Type B Electronic Sounder Beacon (FG-03127MB)  Notes: 1. Meets the requirements of EN54-3: 2001 at the following tones: 1-Alternating Tones 800/970Hz at 2Hz 2-Sweeping 800/970Hz at 7Hz 2. The beacon functionality is not included within the scope of approval.	506e/03

Base:  
FG-03127MB

[To read the Red Book section introduction click here.](#)

[< back to results page](#)



---

The BRE Group website family

BRE Global Approvals listings

[Terms of Use](#) | [How we use cookies](#) | Copyright BRE Global 2019