

Search Results

You are here: [Home](#) » Search Results

Commercial detectors

Fireguard Safety Equipment Co Ltd

Unit 11 Chancel Industrial Estate

Newhall Street

Willenhall

West Midlands

WV13 1NX

United Kingdom

Tel: +44 (0)8450 751042 • Fax: +44 (0)845 2991039

Email: info@fireguard-uk.com • Web: www.fireguard-uk.com

Certificate No 1330a-(cl-3) to EN 54-12:2002

Product	Description	LPCB Ref. No.
FG-BD100	<p>Conventional Reflective Beam Detector</p> <p>Notes:</p> <ol style="list-style-type: none"> Meets the requirements of EN 54-12: 2002 at the following sensitivity settings: <ul style="list-style-type: none"> - Level 1: 2.6 dB High sensitivity - Level 2: 3.8 dB Medium sensitivity - Level 3: 5.8 dB Low sensitivity Suitable for use at the following separation ranges: <ul style="list-style-type: none"> - Span 1: 8 to 20 meters Short Path (1 x mirror reflector required) - Span 2: 20 to 40 meters Short Path (1 x mirror reflector required) - Span 3: 40 to 70 meters Normal Path (4 x mirror reflector required) - Span 4: 70 to 100 meters Long Path (4 x mirror reflector required) <p>Accessories:</p> <p>Mounting Bracket</p> <p>FG-BD100-R 1 x Mirror Reflector</p> <p>FG-BD100-R 4 x Mirror Reflector</p>	1330a/01

[To read the Red Book section introduction click here.](#)

[< back to results page](#)



The BRE Group website family

BRE Global Approvals listings

[Terms of Use](#) | [How we use cookies](#) | Copyright BRE Global 2019